



## Improving Voltage Stability in Kurdistan Power System in Areas with Deficit Power Production by Rescheduling the Active Power Based on PSS/E Simulation

Zainab Pishtiwan Kamal<sup>1,\*</sup>, Kamal Sheikhyounis<sup>2</sup>

Electrical Department, College of Engineering, Salahaddin University, Erbil, Iraq  
[zainabpishtiwan1998@gmail.com](mailto:zainabpishtiwan1998@gmail.com)<sup>1</sup>, [kamal.sheikhyounis@su.edu.krd](mailto:kamal.sheikhyounis@su.edu.krd)<sup>2</sup>

### ABSTRACT

This paper aims to improve the voltage profile using the Static Synchronous Compensator (STATCOM) in the power system in the Kurdistan Region for all weak buses. Power System Simulation studied it for Engineers (PSS\|E) software version 33.0 to apply the Newton-Raphson (NR) method. All bus voltages were recorded and compared with the Kurdistan region grid index ( $0.95 \leq V \leq 1.05$ ), simulating the power system and finding the optimal size and suitable location of Static Synchronous Compensator (STATCOM) for bus voltage improvement at the weakest buses. It shows that Soran and New Koya substations are the best placement for adding STATCOM with the sizes 20 MVAR and 40 MVAR. After adding STATCOM with the sizes [20MVAR and 40MVAR] at Soran to the test, it is seen that the total average change in voltage profile for the system improved results in about 17.34 % in average per unit change for the 28 weakest buses, which provides a good improvement in stability. Also, the system's total active power loss reduced from 123.8 MW without STATCOM to 102.8 MW with STATCOM. The results are encouraging for applying the approach to the power system. This approach stands out due to all bus voltages are within acceptable ranges.

**Keywords:** Voltage Stability Improvement (VSI), Static Synchronous Compensator (STATCOM), PSS®E simulation, Kurdistan Region Power System.

\*Corresponding author

Peer review under the responsibility of University of Baghdad.

<https://doi.org/10.31026/j.eng.2023.11.05>

This is an open access article under the CC BY 4 license (<http://creativecommons.org/licenses/by/4.0/>).

Article received: 07/11/2022

Article accepted: 02/03/2023

Article published: 01/11/2023



# تحسين استقرار الجهد في نظام الطاقة الكريستاني في المناطق التي تعاني من عجز في إنتاج الطاقة من خلال إعادة جدولة الطاقة النشطة على أساس محاكاة PSS/E

زينب بشتيوان كمال<sup>1</sup>، كمال شيخ يونس<sup>2</sup>

قسم هندسة الكهرباء، كلية الهندسة، جامعة صلاح الدين، اربيل، العراق

## الخلاصة

يهدف هذا البحث إلى تحسين ملف الجهد باستخدام الموضع المتزامن الثابت (STATCOM) في نظام الطاقة في إقليم كوردستان لجميع الحالات الضعيفة. تمت دراستها بواسطة برنامج Power System Simulation for Engineers (PSS/E) الإصدار 33.0 لتطبيق طريقة (NR). تم تسجيل جميع الفولتية للحالات ومقارنتها بمؤشر شبكة إقليم كردستان ( $0.95 \leq V \leq 1.05$ ) الذي يحاكي نظام الطاقة وإيجاد الحجم الأمثل والموقع المناسب للموضع المتزامن الثابت (STATCOM) لتحسين جهد الناقل في أضعف الحالات. يظهر أن محطتي Soran و New Koya هما أفضل مكان لإضافة STATCOM بأحجام 20MVAR و 40MVAR. بعد إضافة STATCOM بأحجام [20 و 40] في Soran للاختبار. يلاحظ أن متوسط التغير الإجمالي في ملف الجهد للنظام أدى إلى تحسين حوالي 17.34% في المتوسط لكل وحدة تغيير لأضعف 28 ناقلاً مما يوفر تحسيناً جيداً في الاستقرار. أيضاً ، انخفض إجمالي فقد الطاقة النشطة للنظام من 123.8 ميجاوات بدون STATCOM إلى 102.8 ميجاوات مع STATCOM. النتائج مشجعة لتطبيق النهج على نظام الطاقة. ما يميز هذه الطريقة هو أن جميع الفولتية للحالات تقع ضمن الحدود المسموح بها.

**الكلمات المفتاحية:** تحسين استقرار الجهد (VSI) ، الموضع المتزامن الثابت (STATCOM) ، محاكاة PSS®E ، نظام طاقة إقليم كوردستان.

## 1. INTRODUCTION

Recently, progress in improving the performance of power systems worldwide has been directed toward using advanced control technologies such as the Flexible AC Transmission System (FACTS). Electric power systems transmit and distribute electricity over long distances from power generating stations to consumers, which are typically very large, capital-intensive investments of intricately interconnected parts like power transformers, overhead conductors, underground cables, and generators (Kishore et al., 2010). Due to the economic crisis many developing nations, including Kurdistan, are experiencing, constructing new power plants and transmission lines to provide a reliable, secure, and high-quality electrical supply may go very slowly (Kamarposhti and Lesani, 2011). Because they contain several generating units and transmission links, electrical power systems are complicated (Baghaee et al., 2008). The utilities run the generating units and transmission links at maximum capacity due to the rising daily demand for electricity (Joshi et al., 2016). This lessens the bus voltage stability of the power supply. The transmission network's voltage stability is increased using the Flexible AC Transmission System (FACTS), which regulates the network's active and reactive power flow (Shah et al., 2021). FACTS devices like the Static Synchronous Compensator STATCOM regulate line power flow, bus voltage



magnitudes, and angles (**Simeon et al., 2014**). FACTS, or flexible ac transmission systems, were created to increase transmission capacity across lengthy ac lines and improve the performance of weak ac systems. The three power system states of steady, transient, and post-transient steady state apply to FACTS controllers. The active and reactive power and voltage magnitude can be controlled using FACTS devices (**Yu et al., 2000**). The enhancement of voltage stability, oscillation damping (dynamic stability), and transient stability are all examples of dynamic applications of FACTS controllers (**Mitra and Venayagamoorthy, 2009; Baghaee et al., 2009**). The Facts controller may control shunt impedance, series impedance, voltage, current, and phase angle (**Naveh et al., 2009**). The following are the justifications for employing FACTS (**Singh, 2006**):


- a) to give more effective control than standard control.
- b) to increase control reaction time quickly.
- c) to create dependable and responsive control.
- d) to minimize total system losses
- e) to operate more cost-effectively than constructing a power plant or transmission network.

The 132 kV Kurdistan power network can be used as a case study in this work to examine the impact of using STATCOM on enhancing power system performance. The 132 kV electrical grid in the Kurdistan region will be used as a case study for this work's use of Static Synchronous Compensator STATCOM, a FACTS device, for the performance enhancement of the power system. Static Synchronous Compensator STATCOM is essential for maintaining voltage, compensating for reactive power, enhancing power factor, and raising the voltage on the load buses, along with other things (**Salih et al., 2022; Islam et al., 2013**). Using the Newton Raphson approach, STATCOM was inserted in the 132Kv Kurdistan power system to ensure stability in the voltage profile of the buses (**Thasnas and Siritaratiwat, 2015; Furukakoi 2016**). It is proposed that the Soran and New Koya substations are the optimal locations for installing STATCOM with 20MVAR and 40MVAR. It can be seen that the system's overall average change in voltage profile results in an average per-unit change for the 28 weakest buses of approximately 18.465%, which provides a good improvement in stability (**Azeez and Abdelfattah, 2020; Rasool et al., 2021**). Additionally, with STATCOM the system's overall reactive power losses reduced from 880.4MVAR without STATCOM to 730.4MVAR with STATCOM (**Abido, 2009; Ining, 2021**).

## 2. METHODOLOGY

### 2.1 Simulation by using PSS®E

Voltage stability phenomena are simulated and studied using the PSS®E application. The objective is to showcase how interdependent parts might risk the voltage stability of a system. The software PSS®E-Newton-Raphson load flow technique is used to get voltage profile results on systems without fact (STATCOM) type. Power transmission and distribution grid analysis are two of the most common applications of PSS®E. To enhance the voltage profile, reduced power loss, and minimize system costs, STATCOM is incorporated into the power system network (**Azeez and Abdelfattah, 2020**). The single-line diagram of the Kurdistan power system is shown in **Figs. 1, 2 and 4**. While **Fig. 3** shows the flowchart of the proposed approach.








Figure 2. PSS®E Simulation Model of Kurdistan Region Network



**Figure 3.** Flow Chart for Optimal Size and Location of STATCOM



**Figure 4.** PSS®E Simulation Model of Kurdistan Region Network with STATCOM at Soran & New Koya

## 2.2. Newton Raphson Method for Load Flow

Power flow analysis is one of the most important topics in power system studies (**Milano, 2008**). Due to its benefits and precision, Newton Raphson is the most practical approach for load flow (**Salih, 2022**). The main responsibility of operating a power system is to solve the power flow problem (**Amin, 2019; Acha and Kazemtabrizi, 2013**). The following equations demonstrate the Newton-Raphson load flow method (**Okakwu et al., 2017**).

$$I_i = \sum Y_{ij} V_j n_j = 1 \quad (1)$$

where  $I_i$  is the current injected into the bus  $i$ , writing the polar form equation

$$I_i = \sum |Y_{ij}| |V_j| \angle \theta_{ij} + \delta_j n_j = 1 \quad (2)$$

The current in terms of active and reactive power at bus  $i$ :

$$I_i = P_i - j Q_i V_i^* \quad (3)$$

From these two above equations, it can be reached to:

$$P_i - j Q_i = |V_i| \angle -\delta_i \sum |Y_{ij}| |V_j| \angle (\theta_{ij} + \delta_j) n_j = 1 \quad (4)$$

By separating real and imaginary parts

$$P_i = \sum |Y_{ij}| |V_j| |V_i| \cos(\theta_{ij} - \delta_i + \delta_j) n_j = 1 \quad (5)$$

$$Q_i = \sum |Y_{ij}| |V_j| |V_i| \sin(\theta_{ij} - \delta_i + \delta_j) n_j = 1 \quad (6)$$

These two equations can be rewritten as:



$$\left[ \begin{array}{cc|cc} \frac{\partial P_2^{(k)}}{\partial \delta_2} & \dots & \frac{\partial P_2^{(k)}}{\partial \delta_n} & \frac{\partial P_2^{(k)}}{\partial |V_2|} & \dots & \frac{\partial P_2^{(k)}}{\partial |V_n|} \\ \vdots & & \vdots & \vdots & & \vdots \\ \frac{\partial P_n^{(k)}}{\partial \delta_2} & \dots & \frac{\partial P_n^{(k)}}{\partial \delta_n} & \frac{\partial P_n^{(k)}}{\partial \delta_2} & \dots & \frac{\partial P_n^{(k)}}{\partial \delta_2} \\ \hline \frac{\partial Q_2^{(k)}}{\partial \delta_2} & \dots & \frac{\partial Q_2^{(k)}}{\partial \delta_n} & \frac{\partial Q_2^{(k)}}{\partial |V_2|} & \dots & \frac{\partial Q_2^{(k)}}{\partial |V_n|} \\ \vdots & & \vdots & \vdots & & \vdots \\ \frac{\partial Q_n^{(k)}}{\partial \delta_2} & \dots & \frac{\partial Q_n^{(k)}}{\partial \delta_2} & \frac{\partial Q_n^{(k)}}{\partial |V_2|} & \dots & \frac{\partial Q_n^{(k)}}{\partial |V_n|} \end{array} \right] \quad (7)$$

This matrix can be written as:

$$\begin{bmatrix} \Delta P \\ \Delta Q \end{bmatrix} = \begin{bmatrix} J_1 & J_2 \\ J_3 & J_4 \end{bmatrix} \quad (8)$$

where  $J_1, J_2, J_3$ , and  $J_4$  are Jacobian submatrices.

For  $J_1$  diagonal element:

$$\partial P_i \partial \delta i = \sum |V_i| \sum_{nj=1, j \neq i} |V_j| |Y_{ij}| \sin(\theta_{ij} - \delta_i + \delta_j) \quad (9)$$

For  $J_1$  off-diagonal element:

$$\partial P_i \partial \delta i = -|V_i| |V_j| |Y_{ij}| \sin(\theta_{ij} - \delta_i + \delta_j), j \neq i \quad (10)$$

For  $J_2$  diagonal element:

$$\partial P_i \partial |V_i| = 2|V_i| |Y_{ij}| \cos \theta_{ij} + \sum |V_j| |Y_{ij}| \cos(\theta_{ij} - \delta_i + \delta_j) \sum_{nj=1, j \neq i} \quad (11)$$

For  $J_2$  off-diagonal element:

$$\partial P_i \partial |V_j| = |V_i| |Y_{ij}| \cos(\theta_{ij} - \delta_i + \delta_j), j \neq i \quad (12)$$

For  $J_3$  diagonal element:

$$\partial Q_i \partial \delta i = \sum |V_i| \sum_{nj=1, j \neq i} |V_j| |Y_{ij}| \cos(\theta_{ij} - \delta_i + \delta_j) \quad (13)$$

For  $J_3$  off-diagonal element:

$$\partial Q_i \partial \delta i = -|V_i| |V_j| |Y_{ij}| \cos(\theta_{ij} - \delta_i + \delta_j), j \neq i \quad (14)$$

For  $J_4$  diagonal element:

$$\partial Q_i \partial |V_i| = -2|V_i| |Y_{ii}| \sin \theta_{ii} - \sum |V_j| |Y_{ij}| \sin(\theta_{ij} - \delta_i + \delta_j) \sum_{nj=1, j \neq i} \quad (15)$$

For  $J_4$  off-diagonal element

$$\partial Q_i \partial |V_j| = -|V_i| |V_j| |Y_{ij}| \sin(\theta_{ij} - \delta_i + \delta_j), j \neq i \quad (16)$$

The difference between scheduled and calculated values are  $\Delta P(k)$  and  $\Delta PQ(k)$

$$\Delta(k) = P_{isch} - P_i(k) \quad (17)$$

$$\Delta(k) = Q_{isch} - Q_i(k) \quad (18)$$

The solution for the new values of the voltage and angle are:


$$|V_i|(k+1) = |V_i|(k) + \Delta |V_i|(k) \quad (19)$$



$$(k+1) = \delta i(k) + \Delta \delta i(k) \quad (20)$$

### 2.3. Static Synchronous Compensator (Statcom)

The STATCOM static synchronous generator can be used as a static var compensator when it is shunt-connected, and capacitive or inductive output current can be adjusted independently of the AC system voltage (**Singh, 2006; Anitha and Arul, 2014**). It is a controlling device that can supply or drain reactive power to an electrical network and, when coupled with a power source, can also act as a source of active power. **Fig. 5** depicts a streamlined STATCOM model comprising a coupling transformer, a VSI, and a DC capacitor (**El-Moursi and Sharaf, 2005**).



**Figure 5.** Basic components of STATCOM

The STATCOM output voltage amplitude or the voltage source inverter voltage relative to the AC system voltage can control the reactive power exchange between the STATCOM and the AC system (**El-Moursi and Sharaf, 2005**). Control of the inverter output voltage, on the other hand, may consequence in the supply or removal of active power from the AC system (**Usha and Kumar, 2013; Rasool et al., 2022**). Regulation of the amplitude STATCOM output voltage may lead to one of the following conditions: injection of reactive power into the AC system (**Sagara et al., 2016**), absorption of reactive power from the AC system, or non-injection or permeability of reactive power from the AC system (**Musunuri and Dehnavi, 2010; Kumar et al., 2013**). The STATCOM provides reactive current if its output voltage exceeds the AC system voltage at the connection point. However, it absorbs reactive power if its amplitude exceeds the AC system voltage (**Ahmad, 2013; Hossain et al., 2014**). Connecting a suitable energy storage device across the DC capacitor can raise the active power (**Hossain et al., 2014; Devalkumar and Vyas, 2020**). A few of STATCOM's important purposes are dampening power system oscillation, enhancing the transient stability margin and steady-state power transfer capacity, reducing temporary overvoltage, and effective voltage regulation and control (**Masood et al., 2010**).




### 3. RESULTS AND ANALYSIS

#### 3.1. Case One


The results of the voltage profile, as shown in **Table 1**, after the simulation for the system was run at normal load, suggest that there is under voltage at BB1 SORAN voltage bus bar (0.7556p.u.). HARIR MOB (0.7834p.u.) changed to (1.0 and 0.9653 p.u.), respectively, by adding 20MVAR STATCOM at Soran -substation. However, adding (20MVAR STATCOM at Soran & 20MVAR STATCOM at New Koya) will further modify the voltage profile, changing it to (1.0 and 0.9694) p.u, as illustrated in **Figs. 6 and 7**.

**Table 1.** Voltage without STATCOM, with STATCOM (20MVAR) at SORAN and with STATCOM (20MVAR Soran & 20MVAR New Koya)

No.	Bus Name	Voltage(p.u) Without STATCOM	Voltage(p.u) With STATCOM at Soran	Voltage(p.u) With STATCOM at Soran & New Koya
1	KPS2	0.8258	0.9499	0.9579
2	Qasar Mob.	0.7665	0.9425	0.9516
3	Deralok	0.7778	0.955	0.9641
4	Spilk Mob	0.7702	0.9736	0.9764
5	Bsheryan Mob	0.8532	0.9498	0.9572
6	Qasrok Mob	0.7842	0.9445	0.9522
7	Nahadra Mob	0.7814	0.9472	0.9556
8	Mahat1 Mob	0.7813	0.9452	0.9534
9	Alquush Mob	0.7786	0.9474	0.9562
10	Khatir Mob	0.7727	0.9443	0.9533
11	Zakho U.Mob	0.7575	0.9392	0.9485
12	Shahidan Mob	0.755	0.9378	0.9472
13	New Koya T	0.8937	0.9325	0.9984
14	Akre T2	0.7881	0.9588	0.9637
15	Soran T2	0.7727	0.9711	0.9743
16	Soran T1	0.7741	0.9747	0.9776
17	Khalifan Mob	0.7675	0.982	0.984
18	Rawandz Mob	0.7651	0.9807	0.9827
19	Hndren Mob	0.7563	0.9981	0.9983
20	Balisan Mob	0.7699	0.969	0.9721
21	Harir Mob	0.7834	0.9653	0.9694
22	Basrma Mob	0.7964	0.9549	0.9603
23	BB1 Rezan	0.7337	0.9847	0.9847
24	BB2 Rezan	0.7337	0.9847	0.9847
25	BB1 Koya	0.8959	0.9325	0.9941
26	BB2 Koya	0.8959	0.9325	0.9941
27	BB1 Soran	0.7556	1	1
28	BB2 Soran	0.7556	1	1



**Figure 6.** Low voltage buses without STATCOM, with STATCOM (20MVAR) at Soran and with STATCOM (20 MVAR Soran & 20 MVAR New Koya)



**Figure 7.** Low voltage buses without STATCOM, with STATCOM (20MVAR) at Soran and with STATCOM (20MVAR Soran& 20MVAR New Koya)

### 3.2. Case Two

The results of the voltage profile, as shown in **Table 2**, after the simulation for the system was run at normal load, indicate that there is under voltage at BB1 SORAN voltage bus bar (0.7556p.u) and HARIR MOB (0.7834p.u), which were changed to (1.0 and 0.9653p.u) respectively by adding 40MVAR STATCOM at Soran -substation. However, by including (40MVAR STATCOM at Soran & 40MVAR STATCOM at New Koya), the voltage profile will also be modified to (1.0 and 0.9694) p.u, as shown in **Figs. 8 and 9**.




**Figure 8.** Low voltage buses without STATCOM, with STATCOM (40MVAR) at Soran and with STATCOM (40MVAR Soran& 40MVAR New Koya)

**Table 2.** Voltage without STATCOM, with STATCOM (40MVAR) at SORAN and with STATCOM (40MVAR Soran & 40MVAR New Koya)

No.	Bus Name	Voltage (p.u) Without STATCOM	Voltage (p.u) With STATCOM at Soran	Voltage (p.u) With STATCOM at Soran &New Koya
1	KPS2	0.8258	0.9498	0.9579
2	Qasar Mob.	0.7665	0.9424	0.9515
3	Deralok	0.7778	0.9549	0.964
4	Spilk Mob	0.7702	0.9736	0.9764
5	Bsheryan Mob	0.8532	0.9498	0.9572
6	Qasrok Mob	0.7842	0.9444	0.9521
7	Nahadra Mob	0.7814	0.9471	0.9555
8	Mahat1 Mob	0.7813	0.9452	0.9533
9	Alqush Mob	0.7786	0.9474	0.9561
10	Khatir Mob	0.7727	0.9442	0.9533
11	Zakho U.Mob	0.7575	0.9391	0.9485
12	Shahidan Mob	0.755	0.9377	0.9472
13	New Koya T	0.8937	0.9325	0.9984
14	Akre T2	0.7881	0.9588	0.9637
15	Soran T2	0.7727	0.9711	0.9742
16	Soran T1	0.7741	0.9747	0.9776
17	Khalifan Mob	0.7675	0.982	0.984
18	Rawandz Mob	0.7651	0.9807	0.9827
19	Hndren Mob	0.7563	0.9981	0.9983
20	Balisan Mob	0.7699	0.969	0.9721



21	Harir Mob	0.7834	0.9653	0.9694
22	Basrma Mob	0.7964	0.9548	0.9603
23	BB1 Rezan	0.7337	0.9847	0.9847
24	BB2 Rezan	0.7337	0.9847	0.9847
25	BB1 Koya	0.8959	0.9325	0.9941
26	BB2 Koya	0.8959	0.9325	0.9941
27	BB1 Soran	0.7556	1	1
28	BB2 Soran	0.7556	1	1



**Figure 9.** Low voltage buses without STATCOM, with STATCOM(40MVAR) at Soran and with STATCOM (40MVAR Soran and 40MVAR New Koya)


A comparison of all cases without STATCOM with STATCOM (20 and 40 MVAR) at Soran is shown in **Table 3** and **Fig. 10**. A comparison of all cases without STATCOM, with STATCOM (20 and 40 MVAR) at Soran&New Koya is shown in **Table 4** and **Fig 11**.

**Table 3.** Comparison (20 and 40) MVAR at Soran bus voltage (p.u)


No.	Bus Name	Voltage (p.u) Without STATCOM	Voltage (p.u) With STATCOM at Soran 20 MVAR	Voltage (p.u) With STATCOM at Soran 40 MVAR
1	KPS2	0.8258	0.9499	0.9498
2	QASAR MOB.	0.7665	0.9425	0.9424
3	DERALOK	0.7778	0.955	0.9549
4	SPILK MOB	0.7702	0.9736	0.9736
5	BSHERYAN MOB	0.8532	0.9498	0.9498
6	QASROK MOB	0.7842	0.9445	0.9444
7	MAHADRA MOB	0.7814	0.9472	0.9471
8	ALQUSH MOB	0.7786	0.9474	0.9474
10	KHATIR MOB	0.7727	0.9443	0.9442



11	ZAKHO U.MOB	0.7575	0.9392	0.9391
12	SHAHIDAN MOB	0.755	0.9378	0.9377
13	NEW KOYA T	0.8937	0.9325	0.9325
14	AKRE T2	0.7881	0.9588	0.9588
15	SORAN T2	0.7727	0.9711	0.9711
16	SORAN T1	0.7741	0.9747	0.9747
17	KHALIFAN MOB	0.7675	0.982	0.982
18	RAWANDZ MOB	0.7651	0.9807	0.9807
19	HNDREN MOB	0.7563	0.9981	0.9981
20	BALISAN MOB	0.7699	0.969	0.969
21	HARIR MOB	0.7834	0.9653	0.9653
22	BASRMA MOB	0.7964	0.9549	0.9548
23	BB1 REZAN	0.7337	0.9847	0.9847
24	BB2 REZAN	0.7337	0.9847	0.9847
25	BB1 KOYA	0.8959	0.9325	0.9325
26	BB2 KOYA	0.8959	0.9325	0.9325
27	BB1 SORAN	0.7556	1	1
28	BB2 SORAN	0.7556	1	1
29	%Average	78.721%	96.064%	96.060%



**Figure 10.** Low voltage buses without STATCOM, with STATCOM (20MVAR and 40MVAR) at Soran



**Figure 11.** Low voltage buses without STATCOM, with STATCOM (20MVAR Soran& 20MVAR Newkoya), with STATCOM (40MVAR Soran& 40MVAR Newkoya)

**Table 4.** Comparison (20 and 40) Mvar at Soran&New Koya bus voltages


No.	Bus Name	Voltage(p.u) Without STATCOM	Voltage (p.u) With STATCOM at Soran&Newkoya 20 MVAR	Voltage (p.u) With STATCOM at Soran&Newkoya 40 MVAR
1	KPS2	0.8258	0.9579	0.9579
2	QASAR MOB.	0.7665	0.9516	0.9515
3	DERALOK	0.7778	0.9641	0.964
4	SPILK MOB	0.7702	0.9764	0.9764
5	BSHERYAN MOB	0.8532	0.9572	0.9572
6	QASROK MOB	0.7842	0.9522	0.9521
7	NAHADRA MOB	0.7814	0.9556	0.9555
8	MAHAT1 MOB	0.7813	0.9534	0.9533
9	ALQUSH MOB	0.7786	0.9562	0.9561
10	KHATIR MOB	0.7727	0.9533	0.9533
11	ZAKHO U.MOB	0.7575	0.9485	0.9485
12	SHAHIDAN MOB	0.755	0.9472	0.9472
13	NEW KOYA T	0.8937	0.9984	0.9984
14	AKRE T2	0.7881	0.9637	0.9637
15	SORAN T2	0.7727	0.9743	0.9742



16	SORAN T1	0.7741	0.9776	0.9776
17	KHALIFAN MOB	0.7675	0.984	0.984
18	RAWANDZ MOB	0.7651	0.9827	0.9827
19	HNDREN MOB	0.7563	0.9983	0.9983
20	BALISAN MOB	0.7699	0.9721	0.9721
21	HARIR MOB	0.7834	0.9694	0.9694
22	BASRMA MOB	0.7964	0.9603	0.9603
23	BB1 REZAN	0.7337	0.9847	0.9847
24	BB2 REZAN	0.7337	0.9847	0.9847
25	BB1 KOYA	0.8959	0.9941	0.9941
26	BB2 KOYA	0.8959	0.9941	0.9941
27	BB1 SORAN	0.7557	1	1
28	BB2 SORAN	0.7556	1	1
29	%Average	78.721%	97.186%	97.183%

### 3.2. Power Losses for Kurdistan Region 132 kV, 50 Hz Power System


Although the STATCOM is mostly used to reduce active and reactive power losses in transmission lines in the electrical system. To see the STATCOM effect on the system, the 132 kV Kurdistan power system is used as an example. The summary of the test result is shown in **Figs. 12 and 13**. Total active losses and Reactive total losses are shown in **Table 5**.



**Figure 12.** Total Active power losses with STATCOM

**Table 5.** Power flow losses with and without STATCOM

Power losses	Without STATCOM	With STATCOM at SORAN	With STATCOM at SORAN & NEW KOYA
MW losses	123.8	104.8	102.8
MVAR losses	880.4	744.8	730.4

**Figure 13.** Total Reactive power losses with STATCOM

#### 4. CONCLUSIONS

In this work, a Static Synchronous Compensator STATCOM has been proposed to improve the voltage profile of the power system. The main feature of STATCOM is the compensation of reactive power, one of the efficient ways by which improved and cost-effective performance of power systems. It can be guaranteed to have quick-acting compensating devices that can increase the system's stability. In this work, the performance improvement of power system networks has been examined for the Weakest buses in the power system of the 132kv Kurdistan Region. The study modeled and simulated PSS/E software with and without STATCOM, and all the modeling and simulation were carried out in the environment. The simulation results, graphs, and bar chart confirmed that STATCOM could improve the power system voltage stability. After adding STATCOM with the size [20 and 40MVAR] at Soran and New Koya to the test. It is seen that the total average change in voltage profile for the system improved results in about 18.465 % in average per unit change for the 28 weakest buses, which provides a good improvement in stability. Also, the system's total active power loss reduced from 123.8 MW without STATCOM to 102.8 MW with STATCOM. For future work, it is advisable to rely on other types of FACTS devices and compare them.



## Nomenclature

symbol	description	symbol	description
I	Current (A)	FACTS	Flexible Alternating Current Transmission System
J	Jacobian	KR	Kurdistan Region
P	Power (W)	NR	Newton-Raphson
V	Voltage (V)	PSS®E Software	Power System Simulator for Engineering
$\delta$	angle	STATCOM	Static Synchronous Compensator
		VSI	Voltage Stability Improvement

## REFERENCES

- Abido, M.A., 2009. Power system stability enhancement using FACTS controllers: A review. *The arabian journal for science and engineering*, 34(1B), pp. 153-172.
- Acha, E., and Kazemtabrizi, B., 2013. A new STATCOM model for power flows using the Newton-Raphson method. *IEEE Transactions on Power Systems*, 28(3), pp. 2455-2465. [Doi:10.1109/TPWRS.2012.2237186](https://doi.org/10.1109/TPWRS.2012.2237186)
- Ahmad, A., Shehzad, A., and Shrivastava, V.B., 2013. Power quality improvement using STATCOM in IEEE 30 bus system. *addvance in electronic and electric engineering*, 3(6). pp. 727-732
- Amin, D.H., 2019. Enhancement of Voltage Stability by Using SVC for 30-Bus Power System. *Kurdistan Journal of Applied Research*, 4(2), pp.128-136. [Doi:10.24017/science.2019.2.14](https://doi.org/10.24017/science.2019.2.14)
- Anitha, C., and Arul, P., 2014, March. Enhancement of voltage stability in transmission system using SSSC. In *2014 International Conference on Circuits, Power and Computing Technologies [ICCPCT-2014]* (pp. 30-33). IEEE. [Doi:10.1109/ICCPCT.2014.7054785](https://doi.org/10.1109/ICCPCT.2014.7054785)
- Azeez, T.T., and Abdelfattah, A.A., 2020. Transient stability enhancement and critical clearing time improvement for kurdistan region network using fact configuration. *Journal of Engineering*, 26(10), pp. 50-65. [Doi:10.31026/j.eng.2020.10.04](https://doi.org/10.31026/j.eng.2020.10.04)
- Baghaee, H.R., Mirsalim, M., Kashefi-Kaviani, A., and Gharehpetian, G.B., 2009. Optimal allocation of multi-type FACTS devices to improve security and reduce the losses and fault level using multi-objective particle swarm optimization. *International Review of Electrical Engineering*, 4(6).pp. 1326-1335.
- Baghaee, H.R., Vahidi, B., Jazebi, S., Gharehpetian, G.B., and Kashefi, A., 2008, October. Power system security improvement by using differential evolution algorithm based FACTS allocation. In *2008 Joint International Conference on Power System Technology and IEEE Power India Conference* (pp. 1-6). IEEE [Doi:10.1109/ICPST.2008.4745275](https://doi.org/10.1109/ICPST.2008.4745275)
- Devalkumar, M., and Vyas, S.R., 2020. Voltage Stability Improvement by using STATCOM. *International Research Journal of Engineering and Technology (IRJET)*, 7(3), pp. 4209-4212.
- El-Moursi, M.S., and Sharaf, A.M., 2005. Novel controllers for the 48-pulse VSC STATCOM and SSSC for voltage regulation and reactive power compensation. *IEEE Transactions on Power systems*, 20(4), pp. 1985-1997. [Doi:10.1109/TPWRS.2005.856996](https://doi.org/10.1109/TPWRS.2005.856996)
- Furukakoi, M., Senju, T., and Funabashi, T., 2016, May. Voltage stability improvement of power system using a shunt capacitor. In *Proceedings of the International Conference on Renewable Energies and Power Quality* (pp. 339-344). [Doi:10.24084/repqj14.311](https://doi.org/10.24084/repqj14.311)



Hossain, S., Khan, A.R., and Noor, J.E., 2014. Design of STATCOM for power system stability improvement. *Global J. Res. Eng.*, 14(2), pp. 1-6.

Ining, A.M., Leh, N.A.M., Hamid, S.A., and Muhammad, Z., 2021, December. A Study on Voltage Stability Improvement using STATCOM and UPFC. In *2021 IEEE 9th Conference on Systems, Process and Control (ICSPC 2021)* (pp. 34-39). IEEE. [Doi:10.1109/ICSPC53359.2021.9689145](https://doi.org/10.1109/ICSPC53359.2021.9689145)

Islam, M.N., Kabir, M.A., and Kazushige, Y., 2013. Design and simulation of STATCOM to improve power quality. *International Journal of Innovation and Applied Studies*, 3(3), pp. 871-878.

Joshi, B.S., Mahela, O.P., and Ola, S.R., 2016. Reactive power flow control using Static VAR Compensator to improve voltage stability in transmission system, in 2016 International Conference on Recent Advances and Innovations in Engineering (ICRAIE). [Doi: 10.1109/ICRAIE.2016.7939504](https://doi.org/10.1109/ICRAIE.2016.7939504)

Kamarposhti, M.A., and Lesani, H., 2011. Effects of STATCOM, TCSC, SSSC and UPFC on static voltage stability. *Electrical Engineering*, 93, pp. 33-42. [Doi:10.1007/s00202-010-0187-x](https://doi.org/10.1007/s00202-010-0187-x)

Kumar, K.K., SharathBabu, V., HariBabu, M., and Bhaskar, R., 2013. Performance comparison of SVC and SSSC with POD controller for Power System Stability. *IOSR Journal of Electrical and Electronics Engineering*, 6(2), pp.28-37.

Kishore, P.V., Reddy, S.R., and Kishore, P.V., 2010. modeling and simulation of thirty bus system with DSTATCOM for power quality improvement. *International Journal of Engineering Science and Technology*, 2(9), pp. 4560-4569.

Milano, F., 2008. Continuous Newton's method for power flow analysis. *IEEE transactions on power systems*, 24(1), pp. 50-57. [DOI:10.1109/TPWRS.2008.2004820](https://doi.org/10.1109/TPWRS.2008.2004820)

Mitra, P., and Venayagamoorthy, G.K., 2009. An adaptive control strategy for DSTATCOM applications in an electric ship power system. *IEEE Transactions on power electronics*, 25(1), pp. 95-104. [DOI: 10.1109/TPEL.2009.2024152](https://doi.org/10.1109/TPEL.2009.2024152)

Masood, T., Aggarwal, R.K., Qureshi, S.A., and Khan, R.A.J., 2010, March. STATCOM model against SVC control model performance analyses technique by MATLAB. In *International Conference on Renewable Energies and Power Quality*, 1(8), pp. 1314-1321. [DOI:10.24084/REPQJ08.655](https://doi.org/10.24084/REPQJ08.655)

Musunuri, S., and Dehnavi, G., 2010, September. Comparison of STATCOM, SVC, TCSC, and SSSC performance in steady state voltage stability improvement. In *North American Power Symposium 2010* (pp. 1-7). IEEE. [Doi:10.1109/NAPS.2010.5618971](https://doi.org/10.1109/NAPS.2010.5618971)

Naveh, M.H., Rakhshani, E., and Heidari, R., 2009, March. Application of linear observer on control of subsynchronous oscillations using TCSC. In *2009 International Conference on Power Engineering, Energy and Electrical Drives* (pp. 540-545). IEEE. [Doi:10.1109/POWERENG.2009.4915187](https://doi.org/10.1109/POWERENG.2009.4915187)

Okakwu, I.K., Ogujor, E.A., and Oriaifo, P.A., 2017. Load flow assessment of the Nigeria 330-kV power system. *American Journal of Electrical and Electronic Engineering*, 5(4), pp.159-165. [Doi:10.12691/AJEEE-5-4-6](https://doi.org/10.12691/AJEEE-5-4-6)

Rasool, A.A., Abbas, N.M., and Sheikhyounis, K., 2022. Determination of Optimal Size and Location of Static Synchronous Compensator For Power System Bus Voltage Improvement and Loss Reduction Using Whale Optimization Algorithm. *Eastern-European Journal of Enterprise Technologies*, 1(8), p.115. [Doi:10.15587/11729-14061.12022.251760](https://doi.org/10.15587/11729-14061.12022.251760)

Rasool, A.A., Abbas, N.M., and Sheikhyounis, K., 2021. Contingency Analysis and Ranking of Kurdistan Region Power System Using Voltage Performance Index. *UKH Journal of Science and Engineering*, 5(1), pp. 73-79. [Doi:10.25079/ukhjse.v5n1y2021.pp73-79](https://doi.org/10.25079/ukhjse.v5n1y2021.pp73-79)

Sagara, M., Furukakoi, M., Senju, T., Danish, M.S.S., and Funabashi, T., 2016, October. Voltage stability improvement to power systems with energy storage systems. In *2016 17th International Conference on Harmonics and Quality of Power (ICHQP)* (pp. 7-10). IEEE. [Doi:10.1109/ICHQP.2016.7783463](https://doi.org/10.1109/ICHQP.2016.7783463)



Simeon, M., Tita, W.S., Isaiah, A.A., Ajisegiri, E.S.A., and Joseph, O.A., 2014. Power system's voltage stability improvement using static var compensator. *International Journal of Emerging Technology and Advanced Engineering*, 4(1), pp. 2250-2459.

Shah, S.O., Arshad, A., and Alam, S., 2021, April. Reactive power compensation utilizing FACTS devices. In *2021 International conference on emerging power technologies (ICEPT)* (pp. 1-6). IEEE. [Doi:10.1109/ICEPT51706.2021.9435455](https://doi.org/10.1109/ICEPT51706.2021.9435455)

Singh, S.N., 2006. Flexible AC Transmission Systems (FACTS) controllers: an overview. *International journal of energy technology and policy*, 4(3-4), pp. 236-254. [Doi:10.1504/IJETP.2006.009973](https://doi.org/10.1504/IJETP.2006.009973)

Salih, T.K.M., Hussain, Z.S., and Ahmed, F.S., 2022. Voltage Profile Enhancing Using HVDC for 132KV Power System: Kurdistan Case Study. *Journal of Engineering*, 28(1), pp. 52-64. [Doi:10.31026/j.eng.2022.01.04](https://doi.org/10.31026/j.eng.2022.01.04)

Salih, T.K.M., Hussain, Z., and Ismail, S.Y., 2022. Impact of High Voltage Direct Current Link on Transmission Line in Kurdistan Power System. *Journal of Engineering*, 28(3), pp. 46-59. [Doi:10.31026/j.eng.2022.03.04](https://doi.org/10.31026/j.eng.2022.03.04)

Thasnas, N., and Siritaratiwat, A., 2015. Static voltage stability margin Enhancement using shunt capacitor, SVC and STATCOM. *Applied Mechanics and Materials*, 781, pp. 288-291. [Doi:10.4028/www.scientific.net/AMM.781.288](https://doi.org/10.4028/www.scientific.net/AMM.781.288)

Usha, N., and Kumar, M.V., 2013. Enhancement of power quality in thirty bus system using ZSI based STATCOM. *Int. Journal of Modern Engineering Research*, 3(2), pp. 773-778.

Yu, Y., Jianye, C., and Yingduo, H., 2000, July. STATCOM modeling and analysis in damping power system oscillations. In *Collection of Technical Papers. 35th Intersociety Energy Conversion Engineering Conference and Exhibit (IECEC)(Cat. No. 00CH37022)* (Vol. 2, pp. 756-762). IEEE. [Doi:10.1109/IECEC.2000.870871](https://doi.org/10.1109/IECEC.2000.870871)

## APPENDIX

### A. Load Flow Analysis Before Compensation (without STATCOM)

```
SIEMENS POWER TECHNOLOGIES INTERNATIONAL
50000 BUS POWER SYSTEM SIMULATOR--PSS (R) E-33.5.2
INITIATED ON MON, JAN 23 2023 12:47

SWING BUS SUMMARY:
BUS# X-- NAME --X BASKV      PGEN      PMAX      PMIN      QGEN      QMAX      QMIN
13051 BB EGPP G1  15.000     119.8     125.0     30.0      71.4     72.0     -40.0

          BUS# X-- NAME --X BASKV AREA  V(PU)   V(KV)
          1 DOKAN JOIN2 132.00  1 0.9080 119.85
128.18          3 KPS2      132.00  1 0.8258 109.00
          101.26
          5           132.00  1 0.9108 120.22
127.24          101 QASAR MOB. 132.00  10 0.7665 101.18
119.85          103           132.00  1 0.9182 121.20
126.98          201 DERALOK    132.00  10 0.7778 102.67
115.74
```



301	DERALOK2	132.00	10	0.7778	102.67	302		132.00	1	0.8765	
115.70	401	QERCHWG SMNT	132.00	1	0.9292	122.66	402	SPILK MOB	132.00	1	0.7702
101.67	501		132.00	14	0.9740	128.56	1001	BSHERYAN MOB	132.00	10	0.8532
112.62	1002	QASROK MOB	132.00	10	0.7842	103.51	1003	NAHADRA MOB	132.00	10	0.7814
103.14	1004	MAHAT1 MOB	132.00	10	0.7813	103.14	1005	MAHAT2 MOB	132.00	10	0.7813
103.13	1006	ALQUSH MOB	132.00	10	0.7786	102.77	1007	KHATIR MOB	132.00	10	0.7727
102.00	1008	WEAST MOB	132.00	10	0.7672	101.27	1009	ZAKHO U.MOB	132.00	10	0.7575
99.99	1010	SHAHIDAN MOB	132.00	10	0.7550	99.662	1012	BADR-KALAK T	132.00	10	0.8037
106.09	1013	QARAQUSH T	132.00	10	0.8737	115.33	1301	NEW KOYA T	132.00	13	0.8937
117.97	1302	AKRE T2	132.00	13	0.7881	104.03	1303	AKRE T1	132.00	13	0.7891
104.16	1304	SORAN T2	132.00	13	0.7727	102.00	1305	SORAN T1	132.00	13	0.7741
102.18	1306	KHALIFAN MOB	132.00	13	0.7675	101.32	1308	RAWANDZ MOB	132.00	13	0.7651
101.00	1309	HNDREN MOB	132.00	13	0.7563	99.829	1310	BALISAN MOB	132.00	13	0.7699
101.63	1311	HARIR MOB	132.00	13	0.7834	103.41	1312	BASRMA MOB	132.00	13	0.7964
105.12	1313	SORK MOB	132.00	13	0.8308	109.67	1314	MALA O.MOB	132.00	13	0.8670
114.45	1315	SAFIN MOB	132.00	13	0.8857	116.91	1316	HIWA MOB	132.00	13	0.8905
117.55	1317	PESHASAZ MOB	132.00	13	0.8926	117.83	1318	KASNAZAN MOB	132.00	13	0.9016
119.01	1319	BAGHAMRA MOB	132.00	13	0.9178	121.15	1320	QALAT MOB	132.00	13	0.9107
120.22	1322	KOYA MOB	132.00	13	0.8925	117.81	1323	KAREZAN MOB	132.00	13	0.9102
120.15	1324	HAMREN MOB	132.00	13	0.9102	120.15	1326	BAHRKA MOB	132.00	13	0.8849
116.81	1330	AZADI MOB	132.00	13	0.9152	120.81	1331	TURAQ MOB	132.00	13	0.9172
121.07	1332	NISHTIMAN T	132.00	13	0.9172	121.07	1340	QERCHWG MOB	132.00	13	0.9325
123.09	1341	DEBAGAH MO	132.00	13	0.9329	123.14	1343	CHALOOK MOB	132.00	13	0.8787
115.99	1345	LAJAN MOB	132.00	13	0.9216	121.65	1350	SOR-REZA T2	132.00	13	0.7520
99.259	1351	SMAMAMK MOB	132.00	13	0.9508	125.50	1354	TARJAN MOB	132.00	13	0.9147
120.75	1401	SHAR B T1	132.00	14	0.9677	127.73	1402	SHAR B T2	132.00	14	0.9678
127.75	1403	SHERKUZH MOB	132.00	14	0.9643	127.29	1404	TASL.MOB	132.00	14	0.9759
128.82	1405	MASS C T1	132.00	14	0.9770	128.96	1406	MASS C T2	132.00	14	0.9769
128.95	1407	TAKIA MOB	132.00	14	0.9768	128.94	1408	AZMER SF MOB	132.00	14	0.9688
127.89	1409	RIZGARY T	132.00	14	0.9670	127.64	1410	KAZIWA MOB	132.00	14	0.9638
127.23	1411	KIFRI T2	132.00	14	0.9826	129.70	1412	KIFRI T1	132.00	14	0.9821
129.64	1413	ABDULLA S T1	132.00	14	0.9717	128.27	1415	ABDULLA S T2	132.00	14	0.9731
128.45	1416	GRD-BAZY CE	132.00	14	0.9747	128.66	1417	GRD FACT T	132.00	14	0.9742
128.59	1418	KALAR T2	132.00	14	0.9656	127.46	1419	KALAR T1	132.00	14	0.9557
126.16	1420	KALAR T22	132.00	14	0.9572	126.35	1421	KULAJO MOB	132.00	14	0.9545
126.00											



1425 CHAMCHA MOB 132.00	14 0.9778 129.07	1426 H.SHAR MOB 132.00	14 0.9650
127.38		1427 SHKARTA MOB 132.00	14 0.8579 113.25
127.65		1432 SGP-QULR T11132.00	14 0.9835 129.82
129.89		1434 AGHJALAR MOB132.00	14 0.9517 125.62
117.76		10001 BB1 ZAKHO 132.00	10 0.7544 99.585
99.586		10003 BB1 SUMAIL 132.00	10 0.7739 102.15
101.29		10005 BB3 SUMAIL 132.00	10 0.7739 102.15
102.36		10007 BB2 FAYDA 132.00	10 0.7755 102.37
101.65		10009 BB2 TANAHI 132.00	10 0.7701 101.65
101.23		10011 BB2 WEST DHK132.00	10 0.7669 101.23
102.37		10013 BB2 EAST DHK132.00	10 0.7755 102.37
104.41		10015 BB2 AKRE 132.00	10 0.7910 104.41
102.30		10017 BB2 NORTH DH132.00	10 0.7750 102.30
102.61		10019 BB2 SARSANG 132.00	10 0.7774 102.61
102.30		10021 BB2 SHAKHKE 132.00	10 0.7750 102.30
108.97		10023 BB2 KALAKCHI132.00	10 0.8255 108.97
110.98		10025 BB2 ZANGANAN132.00	10 0.8408 110.99
102.14		10027 BB2 DUHOK GP132.00	10 0.7738 102.14
103.14		10029 BB2 BADRE HF132.00	10 0.7813 103.14
102.17		10031 BB DGPP G1 15.000	10 0.8120 12.180
117.05		13002 BB2 PIRZEEN 132.00	13 0.8868 117.06
118.88		13004 BB2 PARK 132.00	13 0.9006 118.89
120.80		13006 BB2 AZADI 132.00	13 0.9151 120.80
121.19		13008 BB2 WEST EBL132.00	13 0.9180 121.17
116.91		13010 BB2 NORTH EB132.00	13 0.8856 116.90
112.15		13012 BB2 SALAHADD132.00	13 0.8496 112.14
109.55		13014 BB2 SHAQLAWA132.00	13 0.8299 109.55
121.88		13016 BB2 SOUTH EB132.00	13 0.9232 121.87
118.40		13018 BB2 NEW EBL 132.00	13 0.8968 118.38
115.34		13020 BB2 KHABAT 132.00	13 0.8738 115.34
122.26		13022 BB2 POLTEX 132.00	13 0.9261 122.25
124.39		13024 BB2 QUSHTAPA132.00	13 0.9423 124.39
119.88		13026 BB2 EAST EBL132.00	13 0.9081 119.87
117.95		13028 BB2 NEW KOYA132.00	13 0.8936 117.95
118.25		13030 BB2 KOYA 132.00	13 0.8959 118.25
99.746			



13032	BB2	SORAN	132.00	13	0.7556	99.743	13035	BB1	ERBIL	GP132.00	13	0.9520	
125.67							13037	BB1	ERBIL	CC400.00	13	0.9842	
13036	BB2	ERBIL	GP132.00	13	0.9515	125.60	13039	BB1	ERBIL	CE132.00	13	0.9486	
393.66							13041	BB1	KHORMALA	400.00	13	0.9838	
13038	BB2	ERBIL	CC400.00	13	0.9840	393.58	13044	DBS/KIRKUK		132.00	1	0.9334	
125.22							13045	BB2	REZAN		132.00	13	0.7337
13040	BB2	ERBIL	CE132.00	13	0.9485	125.20	13051	BB	EGPP G1	15.000	13	1.0000	
393.53							13052	BB	EGPP G2	15.000	13	1.0000	
13042	BB2	KHORMALA	400.00	13	0.9837	393.47	13053	BB	EGPP G3	15.000	13	1.0000	
123.20							13055	BB	EGPP G5	15.000	13	1.0000	
96.846							13059	BB1	KHABAT	G132.00	13	0.8734	
13045	BB1	REZAN		13	0.7337	96.849	115.30				13	0.8735	
13051	BB	EGPP	G1	15.000	13	1.0000	14001	BB1	CHWAR	QU132.00	14	0.8596	
15.000							14003	BB1	DOK/HPS	132.00	14	0.9093	
13053	BB	EGPP	G3	15.000	13	1.0000	14005	BB1	RANYA		14	0.8593	
15.000							14007	BB1	QALADZE	132.00	14	0.8603	
15.000							14009	BB1	SHARBAZH	132.00	14	0.9647	
115.30							14011	BB1	DOKAN	AB132.00	14	0.9090	
14003	BB1	DOKAN	AB132.00	14	0.9090	119.99	14013	BB1	ZARGATA	132.00	14	0.9634	
113.46							14015	BB1	TAVGA		14	0.9641	
120.02							14017	BB1	TASLUJA	132.00	14	0.9759	
14005	BB1	RANYA		14	0.8593	113.43	14019	BB1	BAZYAN		14	0.9998	
113.43							14025	BB2	AZMAR	132.00	14	0.9639	
113.56							14027	BB2	QULARACY	132.00	14	0.9654	
127.34							14030	SUPER STEEL		142.00	14	0.9769	
14013	BB1	ZARGATA	132.00	14	0.9634	127.17	14035	BB2	PENJWEEN	132.00	14	0.9389	
119.99							14037	BB1	RIZGARI	132.00	14	0.9725	
127.17							14039	BB1	S.SULI	132.00	14	0.9618	
14015	BB1	TAVGA		14	0.9641	127.26	14041	BB1	ABDULA	S132.00	14	0.9712	
127.26							14043	BB1	SULI	CEN132.00	14	0.9705	
14017	BB1	TASLUJA	132.00	14	0.9759	128.82	14045	BB1	BARD	QAR132.00	14	0.9780	
128.81							14047	BB1	SGPP	132.00	14	0.9851	
14019	BB1	BAZYAN		14	1.0000	132.00	14050	MASS STEEL	132.00	14	0.9840		
131.98							14052	BB2	CHAMCHAM	132.00	14	0.9802	
14025	BB2	AZMAR		14	0.9639	127.24	14054	BB2	BAKRAJO	132.00	14	0.9733	
127.24							14027	BB2	QULARACY	132.00	14	0.9654	
127.44							14030	SUPER STEEL		142.00	14	0.9769	
14035	BB2	PENJWEEN	132.00	14	0.9389	123.94	14037	BB1	RIZGARI	132.00	14	0.9725	
123.94							14039	BB1	S.SULI	132.00	14	0.9618	
128.95							14041	BB1	ABDULA	S132.00	14	0.9712	
14037	BB1	RIZGARI		14	0.9725	128.37	14043	BB1	SULI	CEN132.00	14	0.9705	
128.37							14045	BB1	BARD	QAR132.00	14	0.9780	
14039	BB1	S.SULI		14	0.9618	126.96	14047	BB1	SGPP	132.00	14	0.9851	
126.96							14041	BB1	ABDULA	S132.00	14	0.9712	
14041	BB1	ABDULA	S132.00	14	0.9712	128.20	14044	BB2	SULI	CEN132.00	14	0.9705	
128.20							14043	BB1	SULI	CEN132.00	14	0.9705	
14043	BB1	SULI	CEN132.00	14	0.9705	128.11	14045	BB1	BARD	QAR132.00	14	0.9780	
128.11							14047	BB1	SGPP	132.00	14	0.9851	
14045	BB1	BARD	QAR132.00	14	0.9780	129.10	14050	MASS STEEL	132.00	14	0.9840		
129.10							14052	BB2	CHAMCHAM	132.00	14	0.9802	
14047	BB1	SGPP	132.00	14	0.9850	130.01	14054	BB2	BAKRAJO	132.00	14	0.9733	
130.04							14054	BB2	BAKRAJO	132.00	14	0.9471	
14050	MASS STEEL		132.00	14	0.9840	129.89	14056	BB2	S.SADIQ	132.00	14	0.9471	
129.38							14056	BB2	S.SADIQ	132.00	14	0.9471	
14052	BB2	CHAMCHAM	132.00	14	0.9801	129.38	14057	BB1	HALABJA	132.00	14	0.9382	
128.47							14058	BB2	HALABJA	132.00	14	0.9382	
14054	BB2	BAKRAJO	132.00	14	0.9732	128.47	14059	BB1	TANJARO	132.00	14	0.9642	
125.02							14056	BB2	S.SADIQ	132.00	14	0.9471	
14056	BB2	S.SADIQ	132.00	14	0.9471	125.02	14057	BB1	HALABJA	132.00	14	0.9382	
123.85							14058	BB2	HALABJA	132.00	14	0.9382	
14058	BB2	HALABJA	132.00	14	0.9382	123.85	14059	BB1	TANJARO	132.00	14	0.9642	
127.27							14056	BB2	S.SADIQ	132.00	14	0.9471	



14060	BB2	TANJARO	132.00	14	0.9642	127.27	14061	BAZYAN	CEMNT	132.00	14	0.9745
128.63							14067	BB1	KIFRI	132.00	14	0.9510
14063	GRD	DELTA	132.00	14	0.9738	128.54	14069	BB1	KALAR	132.00	14	0.9546
125.53							14071	BB1	DBK/ HPS	132.00	14	0.9670
14068	BB2	KIFRI	132.00	14	0.9510	125.53	14074	TAZA/KIRKUK	132.00	1	0.9633	
126.00							14075	GASN	132.00	14	0.9741	128.58
14070	BB2	KALAR	132.00	14	0.9546	126.00	14081	BB SGPP G1	15.000	14	1.0000	
127.65							14082	BB SGPP G2	15.000	14	1.0000	15.000
14072	BB2	DBK/ HPS	132.00	14	0.9671	127.65	14083	BB SGPP G3	15.000	14	1.0000	
127.16							14084	BB SGPP G4	15.000	14	1.0000	15.000
14075							14088	BB SGPP G8	15.000	14	1.0000	15.000
15.000							14089	BB2	SULI CC	400.00	14	0.9999
15.000							14090	BB1	SULI CC	400.00	14	1.0000
15.000							14091	BB DBK/HP G1	13.800	14	1.0000	
399.96							14092	BB DBK/HP G2	13.800	14	1.0000	13.800
13.800							14101	BB DOK/HP G1	13.800	14	0.9323	
12.865							14106	KURDSAT BB1	132.00	14	0.9642	127.28
127.27							14107	KURDSAT BB2	132.00	14	0.9642	

## B. Load Flow Analysis After Compensation (with STATCOM) at SORAN

BUS#	X--	NAME	--X	BASKV	AREA	V(PU)	V(KV)	BUS#	X--	NAME	--X	BASKV	AREA	V(PU)	V(KV)
1	DOKAN	JOIN2	132.00	1	0.9307	122.86		2	BKJMOB			132.00	14	0.9723	
128.34								4	JOINT1			132.00	1	0.9430	
3	KPS2		132.00	1	0.9499	125.39		6				132.00	1	0.9659	
124.48								102	DOKAN	JOIN1	132.00	1	0.9307		
5			132.00	1	0.9597	126.68		104				132.00	1	0.9633	
127.50								202				132.00	1	0.9532	
101	QASAR MOB.		132.00	10	0.9425	124.42		302				132.00	1	0.9529	
122.86								402	SPILK MOB			132.00	1	0.9736	
103			132.00	1	0.9641	127.26		1001	BSHERYAN MOB	132.00	10	0.9498			
127.15								1003	NAHADRA MOB	132.00	10	0.9473			
201	DERALOK		132.00	10	0.9550	126.06		1005	MAHAT2 MOB	132.00	10	0.9452			
125.82								1007	KHATIR MOB	132.00	10	0.9444			
301	DERALOK2		132.00	10	0.9550	126.06		1009	ZAKHO U.MOB	132.00	10	0.9392			
125.78								1012	BADR-KALAK T	132.00	10	0.9486			
401	QERCHWG SMNT		132.00	1	0.9610	126.86		1301	NEW KOYA T	132.00	13	0.9325			
128.52								1303	AKRE T1	132.00	13	0.9610			
501			132.00	14	0.9753	128.74		1305	SORAN T1	132.00	13	0.9747			
125.38								1308	RAWANDZ MOB	132.00	13	0.9807			
1002	QASROK MOB		132.00	10	0.9445	124.68		1310	BALISAN MOB	132.00	13	0.9690			
125.04															
1004	MAHAT1 MOB		132.00	10	0.9453	124.78									
124.77															
1006	ALQUSH MOB		132.00	10	0.9475	125.07									
124.66															
1008	WEAST MOB		132.00	10	0.9431	124.49									
123.98															
1010	SHAHIDAN MOB		132.00	10	0.9379	123.80									
125.21															
1013	QARAQUSH T		132.00	10	0.9528	125.77									
123.09															
1302	AKRE T2		132.00	13	0.9588	126.57									
126.86															
1304	SORAN T2		132.00	13	0.9711	128.19									
128.66															
1306	KHALIFAN MOB		132.00	13	0.9820	129.62									
129.45															
1309	HNDREN MOB		132.00	13	0.9981	131.75									
127.91															



1311	HARIR MOB	132.00	13	0.9653	127.42	1312	BASRMA MOB	132.00	13	0.9549
126.04						1314	MALA O.MOB	132.00	13	0.9439
1313	SORK MOB	132.00	13	0.9463	124.91	1316	HIWA MOB	132.00	13	0.9484
124.59						1318	KASNAZAN MOB	132.00	13	0.9533
1315	SAFIN MOB	132.00	13	0.9466	124.95	1320	QALAT MOB	132.00	13	0.9577
125.19						1323	KAREZAN MOB	132.00	13	0.9576
1317	PESHASAZ MOB	132.00	13	0.9494	125.31	1326	BAHRKA MOB	132.00	13	0.9479
125.83						1331	TURAQ MOB	132.00	13	0.9634
1319	BAGHAMRA MOB	132.00	13	0.9618	126.96	1340	QERCHWG MOB	132.00	13	0.9642
126.42						1343	CHALOOK MOB	132.00	13	0.9533
1322	KOYA MOB	132.00	13	0.9332	123.18	1350	SOR-REZA T2	132.00	13	0.9976
126.40						1354	TARJAN MOB	132.00	13	0.9671
1324	HAMREN MOB	132.00	13	0.9576	126.40	1401	SHAR B T1	132.00	14	0.9706
125.12						1402	SHAR B T2	132.00	14	0.9795
1330	AZADI MOB	132.00	13	0.9609	126.83	1403	SHERKUZH MOB	132.00	14	0.9779
127.17						1405	MASS C T1	132.00	14	0.9781
1332	NISHTIMAN T	132.00	13	0.9619	126.97	1407	TAKIA MOB	132.00	14	0.9781
127.27						1409	RIZGARY T	132.00	14	0.9686
1341	DEBAGAH MO	132.00	13	0.9646	127.32	1411	KIFRI T2	132.00	14	0.9836
125.83						1413	ABDULLA S T1	132.00	14	0.9730
1345	LAJAN MOB	132.00	13	0.9659	127.50	1416	GRD-BAZY CE	132.00	14	0.9758
131.68						1420	KALAR T2	132.00	14	0.9662
1351	SMAMAMK MOB	132.00	13	0.9821	129.63	1425	CHAMCHA MOB	132.00	14	0.9730
127.65						1427	SHKARTA MOB	132.00	14	0.9788
1401	SHAR B T1	132.00	14	0.9705	128.10	1432	SGP-QULR T11	132.00	14	0.9846
128.12						1434	AGHJALAR MOB	132.00	14	0.9708
1403	SHERKUZH MOB	132.00	14	0.9662	127.54	1435	AGHJALAR MOB	132.00	14	0.9708
129.30						1420	KALAR T22	132.00	14	0.9583
1405	MASS C T1	132.00	14	0.9799	129.34	1425	CHAMCHA MOB	132.00	14	0.9781
129.34						1427	SHKARTA MOB	132.00	14	0.8838
1407	TAKIA MOB	132.00	14	0.9781	129.10	1432	SGP-QULR T11	132.00	14	0.9846
128.10						1434	AGHJALAR MOB	132.00	14	0.9708
1409	RIZGARY T	132.00	14	0.9686	127.86	1435	KOSAR MOB	132.00	14	0.9708
127.49						1411	KIFRI T2	132.00	14	0.9836
1411	KIFRI T2	132.00	14	0.9836	129.84	1416	GRD-BAZY CE	132.00	14	0.9758
129.78						1418	KALAR T2	132.00	14	0.9666
1413	ABDULLA S T1	132.00	14	0.9730	128.43	1420	KALAR T22	132.00	14	0.9583
128.62						1425	CHAMCHA MOB	132.00	14	0.9788
1416	GRD-BAZY CE	132.00	14	0.9758	128.80	1427	SHKARTA MOB	132.00	14	0.8838
128.74						1432	SGP-QULR T11	132.00	14	0.9846
1418	KALAR T2	132.00	14	0.9666	127.60	1434	AGHJALAR MOB	132.00	14	0.9708
126.29						1420	KALAR T22	132.00	14	0.9583
1420	KALAR T22	132.00	14	0.9583	126.49	1425	CHAMCHA MOB	132.00	14	0.9788
126.13						1427	SHKARTA MOB	132.00	14	0.8838
1425	CHAMCHA MOB	132.00	14	0.9788	129.20	1432	SGP-QULR T11	132.00	14	0.9846
127.70						1434	AGHJALAR MOB	132.00	14	0.9708
1427	SHKARTA MOB	132.00	14	0.8838	116.66	1435	KOSAR MOB	132.00	14	0.9708
127.88						1411	KIFRI T2	132.00	14	0.9836
1432	SGP-QULR T11	132.00	14	0.9846	129.96	1416	GRD-BAZY CE	132.00	14	0.9758
130.03						1418	KALAR T2	132.00	14	0.9666
1434	AGHJALAR MOB	132.00	14	0.9708	128.14	1420	KALAR T22	132.00	14	0.9583
125.01						1425	CHAMCHA MOB	132.00	14	0.9788
10001	BB1 ZAKHO	132.00	10	0.9378	123.79	1427	SHKARTA MOB	132.00	14	0.8838
123.79						1432	SGP-QULR T11	132.00	14	0.9846
10003	BB1 SUMAIL	132.00	10	0.9477	125.09	1434	AGHJALAR MOB	132.00	14	0.9708
124.78						1420	KALAR T22	132.00	14	0.9583
10005	BB3 SUMAIL	132.00	10	0.9477	125.09	1425	CHAMCHA MOB	132.00	14	0.9788
124.90						1427	SHKARTA MOB	132.00	14	0.8838
10007	BB2 FAYDA	132.00	10	0.9462	124.90	1432	SGP-QULR T11	132.00	14	0.9846
124.79						1434	AGHJALAR MOB	132.00	14	0.9708
10009	BB2 TANAHI	132.00	10	0.9454	124.80	1435	KOSAR MOB	132.00	14	0.9708
124.45						1411	BB2 WEST DHK	132.00	10	0.9428
10011	BB2 WEST DHK	132.00	10	0.9428	124.45	1408	BB1 TANAHI	132.00	10	0.9454
125.13						10008	BB1 TANAHI	132.00	10	0.9454
10013	BB2 EAST DHK	132.00	10	0.9480	125.13	10010	BB1 WEST DHK	132.00	10	0.9428
124.56						10012	BB1 EAST DHK	132.00	10	0.9480
10015	BB2 AKRE	132.00	10	0.9437	124.56	10014	BB1 AKRE	132.00	10	0.9436
125.22						10016	BB1 NORTH DH	132.00	10	0.9487
10017	BB2 NORTH DH	132.00	10	0.9487	125.23	10018	BB1 SARSANG	132.00	10	0.9545
126.00										



10019	BB2	SARSANG	132.00	10	0.9545	126.00	10020	BB1	SHAKHKE	132.00	10	0.9495
125.33							10022	BB1	KALAKCHI	132.00	10	0.9496
10021	BB2	SHAKHKE	132.00	10	0.9495	125.34	10024	BB1	ZANGANAN	132.00	10	0.9498
125.35							10026	BB1	DUHOK GP	132.00	10	0.9488
10023	BB2	KALAKCHI	132.00	10	0.9496	125.35	10028	BB1	BADRE HF	132.00	10	0.9492
125.38							10030	MOSUL DAM		132.00	1	0.9455
10025	BB2	ZANGANAN	132.00	10	0.9498	125.37	13001	BB1	PIRZEEN	132.00	13	0.9476
125.24							13003	BB1	PARK	132.00	13	0.9541
10027	BB2	DUHOK GP	132.00	10	0.9488	125.25	13005	BB1	AZADI	132.00	13	0.9607
125.30							13007	BB1	WEST EBL	132.00	13	0.9645
10029	BB2	BADRE HF	132.00	10	0.9492	125.30	13009	BB1	NORTH EB	132.00	13	0.9465
124.81							13010	BB2	NORTH EB	132.00	13	0.9465
10031	BB	DGPP G1	15.000	10	0.9818	14.727	13011	BB1	SALAHADD	132.00	13	0.9436
125.08							13013	BB1	SHAQLAWA	132.00	13	0.9467
13002	BB2	PIRZEEN	132.00	13	0.9476	125.08	13015	BB1	SOUTH EB	132.00	13	0.9653
125.94							13016	BB2	SOUTH EB	132.00	13	0.9653
13004	BB2	PARK	132.00	13	0.9541	125.94	13017	BB1	NEW EBL	132.00	13	0.9512
126.82							13018	BB2	NEW EBL	132.00	13	0.9511
13006	BB2	AZADI	132.00	13	0.9607	126.81	13019	BB1	KHABAT	132.00	13	0.9529
127.31							13020	BB2	KHABAT	132.00	13	0.9529
13008	BB2	WEST EBL	132.00	13	0.9644	127.30	13021	BB1	POLTEX	132.00	13	0.9671
124.94							13022	BB2	POLTEX	132.00	13	0.9671
13010	BB2	NORTH EB	132.00	13	0.9465	124.93	13023	BB1	QUSHTAPA	132.00	13	0.9768
124.55							13024	BB2	QUSHTAPA	132.00	13	0.9767
13012	BB2	SALAHADD	132.00	13	0.9436	124.56	13025	BB1	EAST EBL	132.00	13	0.9564
124.96							13026	BB2	EAST EBL	132.00	13	0.9564
13014	BB2	SHAQLAWA	132.00	13	0.9467	124.96	13027	BB1	NEW KOYA	132.00	13	0.9324
127.42							13028	BB2	NEW KOYA	132.00	13	0.9324
13016	BB2	SOUTH EB	132.00	13	0.9653	127.41	13029	BB1	KOYA	132.00	13	0.9325
125.55							13030	BB2	KOYA	132.00	13	0.9325
13018	BB2	NEW EBL	132.00	13	0.9511	125.55	13031	BB1	SORAN	132.00	13	1.0000
125.79							13032	BB2	SORAN	132.00	13	1.0000
13020	BB2	KHABAT	132.00	13	0.9529	125.79	13035	BB1	ERBIL GP	132.00	13	0.9826
127.66							13036	BB2	ERBIL GP	132.00	13	0.9824
13022	BB2	POLTEX	132.00	13	0.9671	127.66	13037	BB1	ERBIL CC	400.00	13	1.0000
128.93							13038	BB2	ERBIL CC	400.00	13	0.9999
13024	BB2	QUSHTAPA	132.00	13	0.9767	128.93	13039	BB1	ERBIL CE	132.00	13	0.9811
126.24							13026	BB2	EAST EBL	132.00	13	0.9564
13026	BB2	EAST EBL	132.00	13	0.9564	126.24	13027	BB1	NEW KOYA	132.00	13	0.9324
123.07							13028	BB2	NEW KOYA	132.00	13	0.9324
13028	BB2	NEW KOYA	132.00	13	0.9324	123.07	13029	BB1	KOYA	132.00	13	0.9325
123.09							13030	BB2	KOYA	132.00	13	0.9325
13030	BB2	KOYA	132.00	13	0.9325	123.09	13031	BB1	SORAN	132.00	13	1.0000
132.00							13032	BB2	SORAN	132.00	13	1.0000
129.71							13035	BB1	ERBIL GP	132.00	13	0.9826
13036	BB2	ERBIL GP	132.00	13	0.9824	129.68	13037	BB1	ERBIL CC	400.00	13	1.0000
400.00							13038	BB2	ERBIL CC	400.00	13	0.9999
13038	BB2	ERBIL CC	400.00	13	0.9999	399.96	13039	BB1	ERBIL CE	132.00	13	0.9811
129.50							13040	BB2	ERBIL CE	132.00	13	0.9810
13040	BB2	ERBIL CE	132.00	13	0.9810	129.49	13041	BB1	KHORMALA	400.00	13	1.0000
400.00							13042	BB2	KHORMALA	400.00	13	0.9999
13042	BB2	KHORMALA	400.00	13	0.9999	399.96	13044	DBS/KIRKUK		132.00	1	0.9682
127.80							13045	BB1	REZAN	132.00	13	0.9847
13045	BB1	REZAN	132.00	13	0.9847	129.99	13046	BB2	REZAN	132.00	13	0.9847
129.99							13051	BB	EGPP G1	15.000	13	1.0000
13051	BB	EGPP G1	15.000	13	1.0000	15.000	13052	BB	EGPP G2	15.000	13	1.0000
15.000							13053	BB	EGPP G3	15.000	13	1.0000
13053	BB	EGPP G3	15.000	13	1.0000	15.000	13054	BB	EGPP G4	15.000	13	1.0000
15.000							13055	BB	EGPP G5	15.000	13	1.0000
13055	BB	EGPP G5	15.000	13	1.0000	15.000	13056	BB	EGPP G6	15.000	13	1.0000
15.000							13059	BB1	KHABAT G1	132.00	13	0.9527
13059	BB1	KHABAT G1	132.00	13	0.9527	125.76	13060	BB2	KHABAT G1	132.00	13	0.9527
125.76							14001	BB1	CHWAR QU	132.00	14	0.8853
14001	BB1	CHWAR QU	132.00	14	0.8853	116.86	14002	BB2	CHWAR QU	132.00	14	0.8853
116.86							14003	BB1	DOK/HPS	132.00	14	0.9319
14003	BB1	DOK/HPS	132.00	14	0.9319	123.02	14004	BB2	DOK/HPS	132.00	14	0.9320
123.02							14005	BB1	RANYA	132.00	14	0.8852
14005	BB1	RANYA	132.00	14	0.8852	116.84	14006	BB2	RANYA	132.00	14	0.8852
116.84												



14007 BB1 QALADZE 132.00	14 0.8864 117.00	14008 BB2 QALADZE 132.00	14 0.8864
117.00			
14009 BB1 SHARBAZH 132.00	14 0.9675 127.72	14010 BB2 SHARBAZH 132.00	14 0.9675
127.71			
14011 BB1 DOKAN AB 132.00	14 0.9317 122.99	14012 BB2 DOKAN AB 132.00	14 0.9317
122.98			
14013 BB1 ZARGATA 132.00	14 0.9654 127.43	14014 BB2 ZARGATA 132.00	14 0.9654
127.43			
14015 BB1 TAVGA 132.00	14 0.9659 127.50	14016 BB2 TAVGA 132.00	14 0.9660
127.51			
14017 BB1 TASLUJA 132.00	14 0.9797 129.31	14018 BB2 TASLUJA 132.00	14 0.9796
129.31			
14019 BB1 BAZYAN 132.00	14 1.0000 132.00	14020 BB2 BAZYAN 132.00	14 0.9999
131.98			
14025 BB2 AZMAR 132.00	14 0.9660 127.51	14026 BB1 AZMAR 132.00	14 0.9660
127.51			
14027 BB2 QULARACY 132.00	14 0.9672 127.67	14028 BB1 QULARACY 132.00	14 0.9672
127.67			
14030 SUPER STEEL 132.00	14 0.9793 129.27	14032 BB MASS CEM 132.00	14 0.9798
129.33			
14035 BB2 PENJWEEN 132.00	14 0.9401 124.09	14036 BB1 PENJWEEN 132.00	14 0.9401
124.09			
14037 BB1 RIZGARI 132.00	14 0.9737 128.53	14038 BB2 RIZGARI 132.00	14 0.9737
128.53			
14039 BB1 S.SULI 132.00	14 0.9631 127.13	14040 BB2 S.SULI 132.00	14 0.9631
127.13			
14041 BB1 ABDULA S 132.00	14 0.9725 128.36	14042 BB2 ABDULA S 132.00	14 0.9724
128.36			
14043 BB1 SULI CEN 132.00	14 0.9718 128.28	14044 BB2 SULI CEN 132.00	14 0.9718
128.27			
14045 BB1 BARD QAR 132.00	14 0.9806 129.44	14046 BB2 BARD QAR 132.00	14 0.9806
129.44			
14047 BB1 SGPP 132.00	14 0.9860 130.15	14048 BB2 SGPP 132.00	14 0.9861
130.17			
14050 MASS STEEL 132.00	14 0.9850 130.02	14051 BB1 CHAMCHAM 132.00	14 0.9812
129.52			
14052 BB2 CHAMCHAM 132.00	14 0.9812 129.51	14053 BB1 BAKRAJO 132.00	14 0.9744
128.62			
14054 BB2 BAKRAJO 132.00	14 0.9744 128.62	14055 BB1 S.SADIQ 132.00	14 0.9483
125.17			
14056 BB2 S.SADIQ 132.00	14 0.9483 125.17	14057 BB1 HALABJA 132.00	14 0.9394
124.00			
14058 BB2 HALABJA 132.00	14 0.9394 124.00	14059 BB1 TANJARO 132.00	14 0.9654
127.44			
14060 BB2 TANJARO 132.00	14 0.9654 127.44	14061 BAZYAN CEMNT 132.00	14 0.9756
128.78			
14063 GRD DELTA 132.00	14 0.9749 128.69	14067 BB1 KIFRI 132.00	14 0.9520
125.67			
14068 BB2 KIFRI 132.00	14 0.9520 125.67	14069 BB1 KALAR 132.00	14 0.9556
126.14			
14070 BB2 KALAR 132.00	14 0.9556 126.14	14071 BB1 DBK/ HPS 132.00	14 0.9680
127.77			
14072 BB2 DBK/ HPS 132.00	14 0.9680 127.78	14074 TAZA/KIRKUK 132.00	1 0.9644
127.30			
14075 GASN 132.00	14 0.9752 128.73	14081 BB SGPP G1 15.000	14 1.0000
15.000			
14082 BB SGPP G2 15.000	14 1.0000 15.000	14083 BB SGPP G3 15.000	14 1.0000
15.000			
14084 BB SGPP G4 15.000	14 1.0000 15.000	14085 BB SGPP G5 15.000	14 1.0000
15.000			
14088 BB SGPP G8 15.000	14 1.0000 15.000	14089 BB2 SULI CC400.00	14 0.9999
399.96			
14090 BB1 SULI CC400.00	14 1.0000 400.00	14091 BB DBK/HP G1 13.800	14 1.0000
13.800			
14092 BB DBK/HP G2 13.800	14 1.0000 13.800	14101 BB DOK/HP G1 13.800	14 0.9545
13.173			
14106 KURDSAT BB1 132.00	14 0.9665 127.58	14107 KURDSAT BB2 132.00	14 0.9665
127.58			

**C. Load Flow Analysis After Compensation (with STATCOM) at SORAN& NEWKOYA**

BUS# V(KV)	X-- NAME	--X BASKV AREA	V (PU)	V (KV)	BUS# X-- NAME	--X BASKV AREA	V (PU)
128.58	1 DOKAN JOIN2	132.00	1 0.9639	127.24	2 BKJMOB	132.00	14 0.9741
125.66	3 KPS2	132.00	1 0.9579	126.44	4 JOINT1	132.00	1 0.9520
127.87	5	132.00	1 0.9666	127.59	6	132.00	1 0.9687
127.24	101 QASAR MOB.	132.00	10 0.9515	125.60	102 DOKAN JOIN1	132.00	1 0.9639
127.39	103	132.00	1 0.9703	128.08	104	132.00	1 0.9651
126.72	201 DERALOK	132.00	10 0.9640	127.25	202	132.00	1 0.9600
126.68	301 DERALOK2	132.00	10 0.9640	127.25	302	132.00	1 0.9597
128.89	401 QERCHWG SMNT	132.00	1 0.9644	127.30	402 SPILK MOB	132.00	1 0.9764
126.34	501	132.00	14 0.9773	129.01	1001 BSHERYAN MOB	132.00	10 0.9571
126.13	1002 QASROK MOB	132.00	10 0.9521	125.68	1003 NAHADRA MOB	132.00	10 0.9555
125.83	1004 MAHAT1 MOB	132.00	10 0.9533	125.84	1005 MAHAT2 MOB	132.00	10 0.9533
125.19	1006 ALQUSH MOB	132.00	10 0.9561	126.21	1007 KHATIR MOB	132.00	10 0.9532
125.30	1008 WEAST MOB	132.00	10 0.9520	125.67	1009 ZAKHO U.MOB	132.00	10 0.9484
126.30	1010 SHAHIDAN MOB	132.00	10 0.9471	125.02	1012 BADR-KALAK T	132.00	10 0.9568
131.79	1013 QARAQUSH T	132.00	10 0.9597	126.68	1301 NEW KOYA T	132.00	13 0.9984
127.48	1302 AKRE T2	132.00	13 0.9637	127.20	1303 AKRE T1	132.00	13 0.9657
129.04	1304 SORAN T2	132.00	13 0.9742	128.60	1305 SORAN T1	132.00	13 0.9776
129.71	1306 KHALIFAN MOB	132.00	13 0.9840	129.88	1308 RAWANDZ MOB	132.00	13 0.9827
128.32	1309 HNDREN MOB	132.00	13 0.9983	131.78	1310 BALISAN MOB	132.00	13 0.9721
126.76	1311 HARIR MOB	132.00	13 0.9694	127.96	1312 BASRMA MOB	132.00	13 0.9603
125.94	1313 SORK MOB	132.00	13 0.9537	125.89	1314 MALA O.MOB	132.00	13 0.9541
126.56	1315 SAFIN MOB	132.00	13 0.9573	126.36	1316 HIWA MOB	132.00	13 0.9588
126.94	1317 PESHASAZ MOB	132.00	13 0.9593	126.63	1318 KASNAZAN MOB	132.00	13 0.9617
127.35	1319 BAGHAMRA MOB	132.00	13 0.9680	127.78	1320 QALAT MOB	132.00	13 0.9648
127.33	1322 KOYA MOB	132.00	13 0.9947	131.30	1323 KAREZAN MOB	132.00	13 0.9646
126.32	1324 HAMREN MOB	132.00	13 0.9646	127.33	1326 BAHRKA MOB	132.00	13 0.9570
127.93	1330 AZADI MOB	132.00	13 0.9671	127.65	1331 TURAQ MOB	132.00	13 0.9692
127.72	1332 NISHTIMAN T	132.00	13 0.9680	127.77	1340 QERCHWG MOB	132.00	13 0.9676
126.72	1341 DEBAGAH MO	132.00	13 0.9679	127.77	1343 CHALOOK MOB	132.00	13 0.9600
131.68	1345 LAJAN MOB	132.00	13 0.9718	128.28	1350 SOR-REZA T2	132.00	13 0.9976
128.30	1351 SMAMAMK MOB	132.00	13 0.9854	130.08	1354 TARJAN MOB	132.00	13 0.9720
128.65	1401 SHAR B T1	132.00	14 0.9745	128.64	1402 SHAR B T2	132.00	14 0.9746



1403	SHERKUZH MOB	132.00	14	0.9688	127.89	1404	TASL.MOB	132.00	14	0.9847	
129.98	1405	MASS C T1	132.00	14	0.9840	129.89	1406	MASS C T2	132.00	14	0.9840
129.89	1407	TAKIA MOB	132.00	14	0.9799	129.34	1408	AZMER SF MOB	132.00	14	0.9728
128.41	1409	RIZGARY T	132.00	14	0.9709	128.16	1410	KAZIWA MOB	132.00	14	0.9687
127.86	1411	KIFRI T2	132.00	14	0.9851	130.04	1412	KIFRI T1	132.00	14	0.9847
129.98	1413	ABDULLA S T1	132.00	14	0.9747	128.67	1415	ABDULLA S T2	132.00	14	0.9762
128.85	1416	GRD-BAZY CE	132.00	14	0.9773	129.01	1417	GRD FACT T	132.00	14	0.9768
128.94	1418	KALAR T2	132.00	14	0.9681	127.79	1419	KALAR T1	132.00	14	0.9583
126.49	1420	KALAR T22	132.00	14	0.9597	126.68	1421	KULAJO MOB	132.00	14	0.9570
126.33	1425	CHAMCHA MOB	132.00	14	0.9803	129.40	1426	H.SHAR MOB	132.00	14	0.9709
128.17	1427	SHKARTA MOB	132.00	14	0.9211	121.58	1431	SGP-QULR T1	132.00	14	0.9712
128.20	1432	SGP-QULR T11	132.00	14	0.9861	130.17	1433	SGP-QULR T2	132.00	14	0.9866
130.23	1434	AGHJALAR MOB	132.00	14	0.9741	128.58	1435	KOSAR MOB	132.00	14	0.9620
126.99	10001	BB1 ZAKHO	132.00	10	0.9471	125.02	10002	BB2 ZAKHO	132.00	10	0.9471
125.02	10003	BB1 SUMAIL	132.00	10	0.9566	126.27	10004	BB2 SUMAIL	132.00	10	0.9544
125.98	10005	BB3 SUMAIL	132.00	10	0.9566	126.27	10006	BB1 FAYDA	132.00	10	0.9551
126.07	10007	BB2 FAYDA	132.00	10	0.9551	126.07	10008	BB1 TANAHI	132.00	10	0.9543
125.97	10009	BB2 TANAHI	132.00	10	0.9543	125.97	10010	BB1 WEST DHK	132.00	10	0.9518
125.63	10011	BB2 WEST DHK	132.00	10	0.9518	125.63	10012	BB1 EAST DHK	132.00	10	0.9567
126.29	10013	BB2 EAST DHK	132.00	10	0.9567	126.29	10014	BB1 AKRE	132.00	10	0.9504
125.45	10015	BB2 AKRE	132.00	10	0.9504	125.46	10016	BB1 NORTH DH	132.00	10	0.9575
126.39	10017	BB2 NORTH DH	132.00	10	0.9575	126.39	10018	BB1 SARSANG	132.00	10	0.9635
127.18	10019	BB2 SARSANG	132.00	10	0.9635	127.18	10020	BB1 SHAKHKE	132.00	10	0.9584
126.51	10021	BB2 SHAKHKE	132.00	10	0.9584	126.51	10022	BB1 KALAKCHI	132.00	10	0.9576
126.40	10023	BB2 KALAKCHI	132.00	10	0.9576	126.40	10024	BB1 ZANGANAN	132.00	10	0.9575
126.38	10025	BB2 ZANGANAN	132.00	10	0.9574	126.38	10026	BB1 DUHOK GP	132.00	10	0.9577
126.42	10027	BB2 DUHOK GP	132.00	10	0.9578	126.43	10028	BB1 BADRE HF	132.00	10	0.9578
126.42	10029	BB2 BADRE HF	132.00	10	0.9578	126.42	10030	MOSUL DAM	132.00	1	0.9544
125.98	10031	BB DGPP G1	15.000	10	0.9905	14.858	13001	BB1 PIRZEEN	132.00	13	0.9569
126.32	13002	BB2 PIRZEEN	132.00	13	0.9570	126.32	13003	BB1 PARK	132.00	13	0.9619
126.97	13004	BB2 PARK	132.00	13	0.9619	126.97	13005	BB1 AZADI	132.00	13	0.9670
127.64	13006	BB2 AZADI	132.00	13	0.9669	127.63	13007	BB1 WEST EBL	132.00	13	0.9701
128.05	13008	BB2 WEST EBL	132.00	13	0.9700	128.05	13009	BB1 NORTH EB	132.00	13	0.9577
126.41	13010	BB2 NORTH EB	132.00	13	0.9577	126.42	13011	BB1 SALAHADD	132.00	13	0.9526
125.74	13012	BB2 SALAHADD	132.00	13	0.9526	125.75	13013	BB1 SHAQLAWA	132.00	13	0.9540
125.93											



13014 BB2 SHAQLAWA132.00	13 0.9540 125.93	13015 BB1 SOUTH EB132.00	13 0.9709
128.16		13017 BB1 NEW EBL 132.00	13 0.9604
13016 BB2 SOUTH EB132.00	13 0.9708 128.15	13019 BB1 KHABAT 132.00	13 0.9598
126.77		13021 BB1 POLTEX 132.00	13 0.9725
13018 BB2 NEW EBL 132.00	13 0.9603 126.77	13023 BB1 QUSHTAPA132.00	13 0.9808
126.69		13025 BB1 EAST EBL132.00	13 0.9638
13020 BB2 KHABAT 132.00	13 0.9598 126.69	13027 BB1 NEW KOYA132.00	13 1.0000
128.37		13029 BB1 KOYA 132.00	13 0.9941
13022 BB2 POLTEX 132.00	13 0.9725 128.36	13031 BB1 SORAN 132.00	13 1.0000
129.46		13035 BB1 ERBIL GP132.00	13 0.9859
13024 BB2 QUSHTAPA132.00	13 0.9807 129.46	13037 BB1 ERBIL CC400.00	13 1.0000
127.22		13039 BB1 ERBIL CE132.00	13 0.9846
13026 BB2 EAST EBL132.00	13 0.9638 127.22	13041 BB1 KHORMALA400.00	13 1.0000
132.00		13044 DBS/KIRKUK 132.00	1 0.9722
13028 BB2 NEW KOYA132.00	13 1.0000 132.00	13046 BB2 REZAN 132.00	13 0.9847
131.22		13052 BB EGPP G2 15.000	13 1.0000
13030 BB2 KOYA 132.00	13 0.9941 131.22	13054 BB EGPP G4 15.000	13 1.0000
132.00		13056 BB EGPP G6 15.000	13 1.0000
13032 BB2 SORAN 132.00	13 1.0000 132.00	13059 BB1 KHABAT G132.00	13 0.9596
130.14		14001 BB1 CHWAR QU132.00	14 0.9226 121.78
400.00		14002 BB2 CHWAR QU132.00	14 0.9225
13036 BB2 ERBIL GP132.00	13 0.9857 130.12	14003 BB1 DOK/HPS 132.00	14 0.9651
129.97		14004 BB2 DOK/HPS 132.00	14 0.9651
13040 BB2 ERBIL CE132.00	13 0.9845 129.96	14005 BB1 RANYA 132.00	14 0.9225
400.00		14006 BB2 RANYA 132.00	14 0.9225
13042 BB2 KHORMALA400.00	13 0.9999 399.97	14007 BB1 QALADZE 132.00	14 0.9241
128.34		14009 BB1 SHARBAZH132.00	14 0.9716 128.25
13045 BB1 REZAN 132.00	13 0.9847 129.99	14011 BB1 DOKAN AB132.00	14 0.9648
129.99		14013 BB1 ZARGATA 132.00	14 0.9682 127.80
15.000		14015 BB1 TAVGA 132.00	14 0.9686 127.86
13051 BB EGPP G1 15.000	13 1.0000 15.000	14017 BB1 TASLUJA 132.00	14 0.9850
15.000		14019 BB1 BAZYAN 132.00	14 1.0000 132.00
13053 BB EGPP G3 15.000	13 1.0000 15.000	14020 BB2 BAZYAN 132.00	14 0.9999
15.000		14025 BB2 AZMAR 132.00	14 0.9689 127.90
13055 BB EGPP G5 15.000	13 1.0000 15.000	14027 BB2 QULARACY132.00	14 0.9698
15.000		14030 SUPER STEEL 132.00	14 0.9840 129.89
13059 BB1 KHABAT G132.00	13 0.9596 126.67	14035 BB2 PENJWEEN132.00	14 0.9418
126.67		14037 BB1 RIZGARI 132.00	14 0.9755 128.77
14001 BB1 CHWAR QU132.00	14 0.9226 121.78	14039 BB1 S.SULI 132.00	14 0.9650
121.78		14002 BB2 CHWAR QU132.00	14 0.9225
14003 BB1 DOK/HPS 132.00	14 0.9650 127.39	14004 BB2 DOK/HPS 132.00	14 0.9651
127.39		14005 BB1 RANYA 132.00	14 0.9225
121.77		14006 BB2 RANYA 132.00	14 0.9225
14007 BB1 QALADZE 132.00	14 0.9241 121.98	14008 BB2 QALADZE 132.00	14 0.9241
121.98		14009 BB1 SHARBAZH132.00	14 0.9716 128.25
128.25		14011 BB1 DOKAN AB132.00	14 0.9648
14013 BB1 ZARGATA 132.00	14 0.9682 127.80	14014 BB2 ZARGATA 132.00	14 0.9682
127.36		14015 BB1 TAVGA 132.00	14 0.9686
127.80		14017 BB1 TASLUJA 132.00	14 0.9850
14019 BB1 BAZYAN 132.00	14 1.0000 132.00	14020 BB2 BAZYAN 132.00	14 0.9999
131.99		14025 BB2 AZMAR 132.00	14 0.9689
127.90		14027 BB2 QULARACY132.00	14 0.9698
14027 BB2 QULARACY132.00	14 0.9698 128.01	14030 SUPER STEEL 132.00	14 0.9840
128.01		14035 BB2 PENJWEEN132.00	14 0.9418
129.88		14037 BB1 RIZGARI 132.00	14 0.9755
124.32		14039 BB1 S.SULI 132.00	14 0.9650
128.77		14040 BB2 S.SULI 132.00	14 0.9650
14039 BB1 S.SULI 132.00	14 0.9650 127.38		
127.38			



14041 BB1 ABDULA S132.00 128.60	14 0.9742 128.60	14042 BB2 ABDULA S132.00 14 0.9742
14043 BB1 SULI CEN132.00 128.51	14 0.9736 128.51	14044 BB2 SULI CEN132.00 14 0.9736
14045 BB1 BARD QAR132.00 129.92	14 0.9842 129.92	14046 BB2 BARD QAR132.00 14 0.9842
14047 BB1 SGPP 132.00 130.36	14 0.9874 130.34	14048 BB2 SGPP 132.00 14 0.9876
14050 MASS STEEL 132.00 129.71	14 0.9865 130.21	14051 BB1 CHAMCHAM132.00 14 0.9826
14052 BB2 CHAMCHAM132.00 128.84	14 0.9826 129.71	14053 BB1 BAKRAJO 132.00 14 0.9761
14054 BB2 BAKRAJO 132.00 125.39	14 0.9760 128.84	14055 BB1 S.SADIQ 132.00 14 0.9499
14056 BB2 S.SADIQ 132.00 124.23	14 0.9499 125.39	14057 BB1 HALABJA 132.00 14 0.9411
14058 BB2 HALABJA 132.00 127.68	14 0.9411 124.23	14059 BB1 TANJARO 132.00 14 0.9673
14060 BB2 TANJARO 132.00 128.98	14 0.9672 127.68	14061 BAZYAN CEMNT132.00 14 0.9771
14063 GRD DELTA 132.00 125.87	14 0.9764 128.89	14067 BB1 KIFRI 132.00 14 0.9535
14068 BB2 KIFRI 132.00 126.33	14 0.9535 125.87	14069 BB1 KALAR 132.00 14 0.9571
14070 BB2 KALAR 132.00 127.95	14 0.9571 126.33	14071 BB1 DBK/ HPS132.00 14 0.9693
14072 BB2 DBK/ HPS132.00 127.50	14 0.9693 127.95	14074 TAZA/KIRKUK 132.00 1 0.9659
14075 GASN 132.00 15.000	14 0.9768 128.93	14081 BB SGPP G1 15.000 14 1.0000
14082 BB SGPP G2 15.000 15.000	14 1.0000 15.000	14083 BB SGPP G3 15.000 14 1.0000
14084 BB SGPP G4 15.000 15.000	14 1.0000 15.000	14085 BB SGPP G5 15.000 14 1.0000
14088 BB SGPP G8 15.000 399.96	14 1.0000 15.000	14089 BB2 SULI CC400.00 14 0.9999
14090 BB1 SULI CC400.00 13.800	14 1.0000 400.00	14091 BB DBK/HP G113.800 14 1.0000
14092 BB DBK/HP G213.800 13.621	14 1.0000 13.800	14101 BB DOK/HP G113.800 14 0.9871
14106 KURDSAT BB1 132.00 128.01	14 0.9698 128.02	14107 KURDSAT BB2 132.00 14 0.9698